

07E:

- 1) 1" Or Smaller Service Line Shall Be Direct Tap Unless Approved By Carmel Utilities.
- 2) Corporation Stop Shall Be Brand And Model Approved By Carmel Utilities.
- 3) Service Line Tap Shall Be Installed With A Min. Horiz. Separation of 24".
- 4) 2 Inch Taps And Smaller Shall Not Be Installed Within Within 18 Inches of Mechanical Joints And Bells.

- * Service Saddle Must Be Omitted For Services 1" And Smaller And Direct Taps Made to Ductile Iron Pipe, Class 350 Or Greater. (Verify With Owner For Pressure Class DIP.)
- ** For all Service Lines Installed Under Pavement Install HDPE Sleeve Under Pavement Section.

DATE: MARCH 2007	CITY OF STANDAF
ARCH 2007 SCALE: NOT TO SCALE	CITY OF CARMEL STANDARD DETAILS
DRAWN BY: CROSSROAD ENGINEERS, PC	RESIDENTIAL WATER SERVI (NO CURB STOP) DETAIL
DRAWING NAME: CW4-3	ATER SERVICE POP) DETAIL